

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client : Flooring Distributers Australia 71 Forsyth Street O'Connor WA 6163

 Test Number
 :
 22-004885

 Issue Date
 :
 21/12/2022

 Print Date
 :
 21/12/2022

Sample Description	Clients Ref : "Eliteplank"	
	Vinyl flooring plank	
	Colour : Samoan Oak	
	End Use : Flooring	
	Nominal Composition : PVC	
	Nominal Thickness : 5mm	



286143

61957

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Chris Campbell

Chris Campbell APPROVED SIGNATORY





Page 1 of 2

ICHAEL A. JACKSON B.Sc.(Hons)

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client :	Flooring Distributers Australia		
	71 Forsyth Street		
	O'Connor WA 6163		

Test Number	:	22-004885
Issue Date	:	21/12/2022
Print Date	:	21/12/2022

AS ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Date of Sample Arrival	06-12-2022						
Date Tested	20-12-2022						
CHF Value	1	2	3	Mean			
Length	7.7	-	-	-	kW/m²		
Width	7.3	7.5	7.5	7.4	kW/m²		
Smoke Value	1	2	3	Mean			
Length	225	-	-	-	%.min		
Width	252	226	229	236	%.min		
Blistering				Yes			

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

286143

61957

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Chris Campbell





Page 2 of 2

ICHAEL A. JACKSON B.Sc.(Hons)