

Comfort Stone Wet Pendulum Test Sheet

Date:	25.10.2020	Test No:	897b
Customer:	FDA		
Test Site:	Slipguard Office		
Tested By:	Martin Ferrier	Time:	10.00am
Australian Standard:	AS4586:2013	Temperature:	20c
Wet Test Equipment Spec:	Wessex Pendulum	Nata Calibration Date:	24/09/2020 (Valid 2yrs)
Machine Type	S885	Serial No:	SK1936
Slider Type:	Slider 96	Slider Release Date:	1/02/2020 (Valid 1yr)
P400 Conditioning swings:	90	90	90
3M 261 Lapping film swings:	60	60	60

Test	Sample	Insitu/Bench Test	Sample Qty	Wet Test						Mean SRV	Class
				Sample 1		Sample 2		Sample 3			
				L1	L2	L3	L4	L5	L6		
				←	→	↑	↓	↙	↘		
T2	Comfort Stone	Bench Test	3	46	48	46	49	47	47	47	P4

Classification	Wet Pendulum SRV Slider 96 Rubber
P5	>54
P4	45-54
P3	35-44
P2	25-34
P1	12-24
P0	<12

Test samples achieved a P4 Classification

Tested to AS4586:2013 & HB198:2014

Slipguard Pty Ltd
 Po Box 673 Wembley WA 6913
 W: slipguard.com.au

M: 0416 183 025

G: marty.ferrier@gmail.com

