

Emission Test Certificate

Friday, 8th November 2013

Supplier: Forbo Flooring Systems (23 Ormsby Place, Wetherill Park NSW 2164)

Sample Description: Forbo Marmoleum

Date Tested: October 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Ecospecifier GreenTag Certification Program	Forbo Marmoleum
Total Volatile Organic Compound emission rate <500 ug/m ² /hr	161 ug/m ² /hr
4-phenylcyclohexene emission rate <50 ug/m ² /hr	<6 ug/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130906